

ARWADEX-11
CAIRO
EGYPT – APRIL 2017



CONSULTING ENGINEERING CO.

DESALINATION TODAY AND FUTURE IN A CHANGING WORLD

KEYNOTE SPEECH


Presented by

DR YAHYA ELSAIE

- **WORLD'S FIRST SUCCESSFUL LAND BASED MSF DEVELOPMENT, EGYPTIAN SUPERVISED 1957 – SHUWAIKH – KUWAIT UNDER DEVELOPMENT CONTRACT WITH M/S WESTINGHOUSE (REPLACES OLD UNSUCCESSFUL SUBMERGED TUBE DESIGN). THIS TECHNIQUE PROVED TO BE THE MOST RELIABLE TO DATE.**
- **DESIGN DEVELOPMENT – MSF (*KUWAIT, ABU DHABI, KSA, BAHRAIN, OMAN, LIBYA*): 250,000 IGPD TILL 7 MIGD UNIT SIZES**



SHUWAIKH (A) DISTILLATION PLANT



EVAPORATOR SHUWAIKH (A) DISTILLATION PLANT



CONSULTING ENGINEERING CO.

Formerly Dr. M.H. Ali El-Saie Consulting Engineers



ISO 14001 & OHSAS 18001

DESALINATION SECTOR

GHUBRAH II




WORKS

MSF

TVC

RO



GHUBRAH PLANT

TYPICAL THERMAL PLANTS CONFIGURATION

Dual purpose plants

- Extraction Condensing (EC) Steam Turbines (ST) coupled to MSF or TVC
- Back Pressure (BP) Steam Turbine (ST) coupled to MSF or TVC
- Gas Turbine (GT), EHR Boiler (HRSG) and MSF or TVC.
- Combined Cycle Power Coupled to MSF or TVC

AL TAWEELAH (A) GAS TURBINE POWER & DESALINATION PLANT



**3 GAS TURBINE 117
MW ISO RATING**

**DESALINATION
UNITS 3X6/7.2 MIGD**

**SEAWATER INTAKE
& OUTFALL**

COMPLETED 1989

**UNIT 4 7.2/8 MIGD,
160 T/HR AUXILIARY
BOILER**

COMPLETED 1996

**LOCATION
ABU DHABI**

GHUBRAH POWER & DESALINATION PLANT - OMAN



PHASES:
I 1X5/6 MIGD,
II 5/6 MIGD,
III 1X5/6 MIGD,
V 1X5/6 MIGD,
VI 1X6/7 MIGD
COMPLETED 2000

UMM AL-NAR POWER & DESALINATION PLANT – ABU DHABI



UMM AL-NAR EAST 3X5/6 MIGD
EAST EXT. 3X6/7.2 MIGD
UMM AL-NAR WEST 6X4 MIGD
WEST EXT. 7&8 4X5/6 MIGD

Thermal desalination *optimization*.

- *Scaling.*
- *Top brine temperature*
- *Antiscalants*
- *Materials.*
- *Gain ratio.*



Consulting Engineering Co.

Oil Price Variation in past 60 Years (US\$/Barrell)






FIGURE 2: FOSSIL FUEL PRICE: HISTORICAL EVOLUTION AND PROJECTIONS



Source: PROMETHEUS modelling, NTUA, E3M-Lab





Consulting Engineering Co.

FIGURE 3 : POWER AND INVESTMENTS






Figure-6 Typical Comparison Between Thermal Desalination And Reverse Osmosis (RO) For Capacity 20,000m³/Day

S.N.	ITEM	THERMAL DESALINATION PLANTS		RO PLANTS
		MSF	TVC	
1	Raw Water m ³ / m ³ Product Factor	12	6	3
2	Raw Water Pretreatment	Normal	Normal	Extensive pretreatment
3	Capital Cost Millions US\$	30	26	24
4	Required Steam	Requires steam from waste heat (e.g. in combination with gas turbines, steam turbines, APG, NPP, CSP OR CC) for better Economy	Requires steam from waste heat (e.g. in combination with gas turbines, steam turbines, APG, NPP, CSP OR CC) for better Economy	Not Required
5	Power KWH/m ³ Product	4	1.5	3
6	Spare Parts	More Wear & Tear Parts	Wear & Tear Parts	<ul style="list-style-type: none"> - Less Wear & Tear Parts - Membrane Replacement (high cost)
7	O&M	Normal	Normal	Chemist is required continuously
8	Reliability	Excellent	Good	Operation errors present high risk

MIRFA POWER & DESALINATION PLANT – ABU DHABI



**4X61 ISO MW GAS TURBINES
3X5.4 MIGD
COMPLETED 1997**

ABU TARABA DESALINATION PLANT - LIBYA



**CAPACITY 3X2.9 MIGD (40,000 M3/D)
COMPLETED 2007**



**1st PASS RO – DELMA ISLAND AT ABU DHABI - 3.3 USMGD
Pass 2 completed 2012**



**SUR IWP RO PLANT 150,000 M3/DAY – OMAN
DEVELOPER: VEOLIA & BEC**

Middle East & North Africa (MENA) *(FROM Fichtner)*




Figure 8 - Table of capital costs per KW, types of fuel Current Outlook

Type	Capital \$/kW	Life (Y)	Efficiency	Fuel Type	Fuel Cost US\$/M-BTU
Steam	1000	30	40	NG	3
GT	800	25	33-35	NG	3
CC	900	25	50-55	NG	3
Coal	2500	30	36	Coal	3-4
CSP	4000	25	N/A	IR	-

CRITERIA FOR FUTURE SCENARIOS

- Fuel type & cost variation
- Capital cost decrease & economies of scale
- Intake & Outfall
- Dual and/or CC mode
- PV or CSP renewables as source of future power
- Intake water salinity
- Energy storage (CSP)
- Lifetime of main equipment

LOCALISATION

- Thermal Plants Similar to shipbuilding, available facilities in shipbuilding
- RO Plants
 - Most BOP can be locally manufactured except:
 - Membrane (on going trials to establish future facilities)*
 - HP pump (can be manufactured under license)*
 - Energy recovery device*
- Training A dire need. Should be institutionalized & promoted



CONSULTING ENGINEERING CO.

Formerly Dr. M.H. Ali El-Saie Consulting Engineers

EMS 14001 & OHSAS 18001



SEAWATER INTAKES

- Open Channel Rubble Mound structure
- Pipelines Trestle Structure on Piles with offshore intake pumping chamber
- Pipe on Seabed with onshore pumping stations
- Beach Wells

INTAKE RECIRCULATION STUDIES




Figure 1: The location of the intakes and outfalls pipelines in Alternative-1




Figure 2: Salinity distribution (mg/l) at layer 5 (Near to bottom) with low water level (ebb tide)




Figure 4: Temperature distribution at layer 5 (Near to bottom) with low water level (ebb tide)




Figure 3: Salinity distribution (mg/l) at layer 2 (under surface layer) with low water level (ebb tide)





Figure 5: Temperature distribution at layer 3 (at middle depth) with low water level (ebb tide)

VALUE (\$M) OF PROJECTS AROUND THE WORLD



Total value of projects 24,467,000,000 \$
Accumulated 5,500,000 m³/day

THANK YOU!

DR. Y. M.H. ALI EL-SAIE
CONSULTING ENGINEERING CO.
(CEC)

END OF SESSION